

**TAMIL NADU GENERATION AND DISTRIBUTION CORPORATION LTD.  
(Technical Branch)**

O/o. Chief Engineer/Commercial,  
144, Anna Salai, Chennai-2.

**Memo.No.CE/Comml/SE/EE/R&C/AEE1/F.Solar NFI/D.118/19,dt.21.05.2019**

Sub: TANGEDCO – Tamil Nadu Solar Energy Policy-2019 – Order on Rooftop Solar Generation by the TNERC – Implementation of Solar net feed-in connection - Modification of working instruction already issued vide Memo. dt.10.05.2019- Reg.

Ref: (i) Tamil Nadu Solar Policy-2012.  
(ii) Hon'ble TNERC's Order No.03, dt.13.11.2013.  
(iii) Tamil Nadu Solar Energy Policy-2019.  
(iv) Hon'ble TNERC's Order No.03 of 2019, dt.25.03.2019.  
(v) Memo.No.CE/Comml/EE/R&C/AEE1/F.Solar NFI/D.099/19, dt.10.05.2019

\*\*\*\*\*

In continuation to the working instruction for implementation of Solar net feed-in connection already issued vide reference (v), Sl.No. 8 of the above said instruction may be read as follows:

8. The consumers under the solar net feed-in scheme will have to install two meters, one is for measuring solar power generation and the other is to measure import and export of energy. However the installation of solar generation meter may not be insisted on for all categories of consumers until further instruction. The first meter, solar generation meter shall be placed after the inverter at the ground floor of the premises to facilitate easy access for meter reading. The second meter shall be a bi-directional meter which will replace the existing consumer meter (single phase or three phase) for commercial settlement of energy imported and exported. The first and the second meter will have to be installed at the same location where existing meter for recording consumption of energy is installed. The meters shall adhere to the standards specified by the Central Electricity Authority (Installation and Operation of Meters) Regulation, 2006 and as amended from time to time and Commission's relevant regulations/orders as amended from time to time. TANGEDCO will procure, test and install the meters. The cost of new/additional meters for the net feed-in scheme and the installation and testing charges shall be borne by the consumers.

**(BY ORDER OF THE CHAIRMAN CUM MANAGING DIRECTOR)**

U.S. Pongiannan,  
Chief Engineer/Commercial

To  
All Chief Engineers/Distribution Region.  
All Superintending Engineers/EDC.  
Copy to CMD/TANGEDCO's table.  
Copy to JMD/TANGEDCO's table.  
Copy to MD/TANTRANSCO  
Copy to Director/Distribution.

Copy to Director/Generation.  
Copy to Director/Operation.  
Copy to Director/Transmission & Projects.  
Copy to Director/Finance/TANGEDCO.  
Copy to Director/Finance/TANTRANSCO.  
Copy to the Chief Engineer/Planning and RC  
Copy to the Chief Engineer/NCES.  
Copy to the Chief Engineer/MM,  
Copy to the Chief Engineer/IT,  
Copy to the Chief Financial Controller.